



- NOTES:**
1. REFER TO SHEET D2 & D3 FOR STANDARD PIT DIMENSIONS & FOR FRAME, GRATE & LINTEL DETAILS.
 2. 3 mm CLEARANCES TO BE LEFT AROUND GRATE.
 3. CHANNEL TO BE SHAPED AS PER STANDARD DRAWING D2.
 4. FOR PITS DEEPER THAN 1.0 m STEP IRONS AT 300 mm CENTRES SHALL BE INSTALLED (FIRST STEP IRON AT 450 mm FROM PIT FLOOR).
 5. PITS OVER 1.5 m TO BE CORBELLED TO SUIT STANDARD FRAME & LID.
 6. ALL CONCRETE TO BE N32 STRENGTH GRADE.
 7. THE PIT FLOOR TO BE POURED PRIOR TO CONSTRUCTING THE WALLS.
 8. GRATES PLACED ADJACENT TO BLUESTONE SHALL BE PAINTED WITH BLACK RUST PROOFING COMPOUND. ALL OTHER GRATES SHALL BE GALVANISED.

CITY OF MONASH

DOUBLE GRATED SIDE ENTRY PIT

AMENDED GRATE SIZES MAR. 2013

DIRECTOR INFRASTRUCTURE: 		
DRAWN: W.Du Feb 2011	SCALE: 1:20	SHEET:
DWG NAME: STDWG D 06	21500	D 06
		REV: C JUN15